EMPSCO

ENGINEERING MANAGEMENT & PLANNING SERVICES CORPORATION

August 17, 2017

Ms Carl V. Dominguez
Acting Director
Guam Bureau of Statistics and Plans
P.O. Box 2950
Hagatna, Guam 96932
Tel (671) 477-4201
Fax (671) 477-1812

Attention: Ms Tina Mafnas, Planner

Guam Coastal Resources Management Program

Subject: Bayside Wastewater Pump Station Rehabilitation Project

Including Expanded Design Scope for Bank Protection

Project- GWA Project No. S15-007-BND

Guam Coastal Management Act Federal Consistency Consultation

Dear Sir/Madam,

On behalf of Guam Waterworks Authority, we would like to initiate the needed consultation with your office to seek approval of the proposed sewage pump station rehabilitation project.

In this regards, we are submitting herewith for your review a set of the proposed project design plans and specifications which depicts the scope of the rehabilitation work as follows:

Existing Sewage Pump Station

- Building a new retaining wall to resolve the eroding area at southwest corner of site
- Provide new chain link fencing with vehicle gate around the station,
- Provide two new two new submersible pumps (one duty and one backup) in operation for the station wet well and re-configure discharge piping and valves to increase hydraulic efficiency and eliminate trip hazards
- Provide new electrical power and pump control system and components
- Provide new standby power generator with all controls
- Improve the area lighting with motion detector controls
- Restore the adequacy of the existing electrical grounding system
- Provide new exhaust ventilation system to the sanitary wet well
- Provide operable hatch cover on concrete collar for the existing sewage manhole
- Provide new vandal-proof metal grille enclosure around generator
- Provide new hollow metal door for station entry and provide one louver window
- Paint all existing and new surfaces of the existing building

Easement Entrance

Rock revetment (after-the-fact) installed by DPW/GPA

PROJECT: Bayside SPS Rehabilitation Project
Letter to BSP August 17, 2017

• Provide new barricade pipe gate for vehicle access control.

Other documents included with this submission are the following:

- Guam Coastal Resources Management Form Dated August 17, 2017
- 2017 Nationwide PCN Form

During the construction of the new retaining walls at the pump station and other minor earthworks, the plans calls for the contractor to provide adequate temporary erosion and sedimentation control protection measures.

Detailed Plans and Specifications that will enable the contractor to properly provide and implement these necessary environmental protection and control systems have been included such as silt fences and soil storage systems. The contractor will be required to submit an environmental protection plan and a dewatering plan if necessary for review and approval prior to starting any construction.

We certify that the proposed activity complies with the enforceable policies of the Guam Coastal Management Program and will be conducted in a manner consistent with such Program.

If you have any immediate questions concerning this project, kindly contact me at our office number indicated herewith or my mobile 671-4827928.

Thank you very much and we look forward to your guidance.

Sincerely

sagani Z.Dayao Jr., P.E.

Project Manager

Attachments:

- Proposed Plans and Specifications
- GCMP Assessment Form
- Draft USACOE PCN Application

Cc: Thomas F. Cruz, P.E., Guam Waterworks Authority

GOVERNMENT OF GUAM GUAM WATERWORKS AUTHORITY

BAYSIDE PUMP STATION REHABILITATION

PROJECT NUMBER S15-007-BND

CHALAN GOVERNOR CARLOS CAMACHO,

TAMUNING, GUAM



